



# Mims Engineering Inc.

112 Southside Square, Suite B Huntsville, AL 35801 Phone: (256)881-4126 Fax: (256)880-6743

**PROJECT: Boiler Replacement at School of Engineering for Alabama A&M University  
Addendum No. One  
May 22, 2018  
B.C.: No. 2018249**

TO PROSPECTIVE BIDDERS:  
THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE BIDDING DOCUMENTS DATED MAY 2, 2018, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE PROPOSAL FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.

THIS ADDENDUM CONSISTS OF 1 PAGES



## CHANGES TO THE PROJECT MANUAL

### SPECIFICATIONS:

#### **DIVISION 00100 BID DOCUMENTS AND FORMS:**

A. Advertisement for Pre-Bid:

1. Change the date of the Pre-Bid to May 29, 2018.

B. Advertisement for Bid:

1. Change the date of the Bid to June 7, 2018.

#### **SECTION 008000 APPENDIX C:**

Time Allowance:

1. Change the time allowance to 60 calendar days from Notice to Proceed.

## CHANGES TO THE DRAWINGS

### Mechanical Drawings:

1. Drawing M101 Mechanical Demolition notes: Clarification existing power wiring and control wiring to remain for reuse as existing equipment is 18 amps and required equipment is 14 amp. Contractor to field verify PRIOR to bid and advise of any conflicts should they arise.
2. Drawing M101 Mechanical Reference Notes, Add the following to end of note 1 "All Electrical work will be performed by Licensed Electrician."
3. Drawing M102: Boiler Schedule, Boiler model number should read CHN2072.

**END OF ADDENDUM**