



SECTION 00 91 12

ADDENDUM NUMBER 3

PARTICULARS

- 1.01 DATE: JANUARY 11, 2021
- 1.02 PROJECT: PRIMARY POWER DISTRIBUTION FOR BUS FACILITIES
- 1.03 PROJECT NUMBER: DCM NO. 2020760
- 1.04 OWNER: ALABAMA A&M UNIVERSITY
- 1.05 ARCHITECT: NOLA | VAN PEURSEM ARCHITECTS, PC

TO PROSPECTIVE BIDDERS

- 2.01 THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE BIDDING DOCUMENTS DATED DECEMBER 1, 2020, WITH AMENDMENTS AND ADDITIONS NOTED BELOW.
- 2.02 ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE PROPOSAL FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.
- 2.03 THIS ADDENDUM CONSISTS OF 1 PAGE.

CHANGES TO THE PROJECT MANUAL

3.01 GENERAL CLARIFICTIONS

- A. The use of refurbished transformers will be acceptable. Refurbished transformers must include a 2-year warranty.

3.02 SECTION 26 95 00 – ELECTRICAL DISTRIBUTION:

- A. Paragraph 2.7.A: Transformer KVA (bus wash) shall be 150kVA (drawings are correct).
- B. Paragraph 2.7.B: Delete this paragraph in its entirety.
- C. Paragraph 2.7.C: Transformer KVA (bus wash) shall be 100kVA (drawings are correct).

CHANGES TO THE DRAWINGS (NOT USED)

END OF ADDENDUM NUMBER 3